

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

VAN AMBATIELOS
PRESIDENT

E. FELICIA BRANNON
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL
GEORGE HOVAGUIMIAN
JAVIER NUNEZ

CITY OF LOS ANGELES
CALIFORNIA



ERIC GARCETTI
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

RAYMOND S. CHAN, C.E., S.E.
GENERAL MANAGER

FRANK BUSH
EXECUTIVE OFFICER

Maxie Palmer III
Diversi Tech Corp.
2175 East Park Drive
Conyers, GA 30013

Telephone: 678-542-3600

Models:

CS-1 (tee fitting on drain line), CS-2 (elbow fitting on drain line), CS-3 (clip bracket on drain pan)

PLEASE REFER TO THE APPLICATION NUMBER ON ALL CORRESPONDENCE, PHONE CALLS & SAMPLES

The item processed under the above file number has been tested, examined and found to comply with applicable Los Angeles Plumbing Code (LAPC) and/or Los Angeles Mechanical Code (LAMC) and is hereby approved unless revoked for cause.

This letter or the letterhead copy may not be reproduced for use in labeling or advertising, but copies of this letter may be used within your organization and shown as evidence of approval.

CONDITIONS OF APPROVAL:

- 1. Installation of this product eliminates the need for a secondary condensate drain.**
- 2. These products are not allowed to be installed within air plenums.**
- 3. A mechanical permit shall be obtained per Section 95.111.0 of the LAMC, 2014 Edition.**

Each item shall have the name or trademark of manufacturer and model number where it will be visible for inspection.

In order to renew this approval, an application and reexamination fee must be submitted on or before the expiration date shown above. Arrangement shall be made to remove any test samples remaining in the Laboratory. Samples remaining after 21 days from the date of this notice will be shipped collect by the most convenient carrier or disposed of in accordance with applicable regulation.

Manuel Hernandez
Mechanical Testing Laboratory, Test Engineer

File Number: M-140048

Effective Date: 11/19/2014

Expiration Date: 12/01/2015

Manufacturer: STANDEX

Item: CONDENSATION OVERFLOW SHUT-OFF SWITCH